


TÜV NORD CERT GmbH
herewith declares that

Yingli Energy (China) Co., Ltd.
No.3399, Chaoyang North Road
Baoding City, Hebei Province, 071051
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:



Description of product (details see Annex 2):

PV Modules with 6" Mono-crystalline Silicon Solar Cells (P type)

Valid until: 2022-08-06

Tested according to: IEC / EN 61215:2005;
IEC 61730-1:2004+A1:2011+A2:2013 / EN 61730-1:2007+A1:2012+A2:2013;
IEC 61730-2:2004+A1:2011 / EN 61730-2:2007+A1:2012.

Registered No.: 44 780 17 406749 - 145

Manufacturer: see Annex 1

Test Report No.: 492010901.001

File No.: SHV04001/17



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Essen, 2017-08-07

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 17 406749 - 145

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: SHV04001/17

2017-08-07

Manufacturer:

Manufacturer: **Yingli Energy (China) Co., Ltd.**
No.3399, Chaoyang North Road
Baoding City, Hebei Province, 071051, P.R. China

Factory inspection report no.: 862010336.001

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with 6" Mono-crystalline Silicon Solar Cells (P type) 72 cells: YLxxxD-36b (xxx=285-390, in steps of 5) 72 cells: YLxxxDD-36b (xxx=285-390, in steps of 5) 60 cells: YLxxxD-30b (xxx=240-325, in steps of 5) 60 cells: YLxxxDD-30b (xxx=240-325, in steps of 5)
Maximum system voltage:	1000V
Fuse rating:	15 A
Application class:	Class A
Electrical protection class:	Class II
Fire safety class:	Class C
Rated mechanical load:	5400Pa

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products